

Department	Standard Components	Room Tag:	1560
Room Name	Bay - Mobile Equipment, 4m2	Room Code:	BMEQ-4-SJ
Net Room Area Briefed	4.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	4.00 M2		
Hours of Operation	24 Hours		
Occupancy	N/A		
Also covers these Rooms			
Description/ Special Requirements	<p>An open storage bay for one or more items of mobile equipment in frequent use which may include wheelchairs, mobile scales, commode chairs, patient lifting devices or other mobile equipment.</p> <p>Special Design Requirements: The Bay should be deep enough to ensure equipment stored does not impede corridor circulation; bay depth 800 -1200mm depending on equiption to be stored.</p> <p>Electrical equipment that requires recharging may be stored in this space whilst recharging, therefore provision of appropriately located power outlets will be required.</p>		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		carpet optional
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or timber skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		
4022	Wall protection	Composite	Prefinished PVC	Crash rail at 350 AFFL		optional

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
7400	Trolley: equipment	Furniture/ Fitting	3	1	as required
24200	Wheelchair	Furniture/ Fitting	3	2	as required

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		

Department | **Standard Components**
Room Name | **Bay - Mobile Equipment, 4m2**

Room Tag: 1560
Room Code: BMEQ-4-SJ

ID	Description	Service Category	Qty	Selection / Remarks
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	2	For recharging of electrical equipment