

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag:</b>	<b>2130</b>
<b>Room Name</b>	<b>Daylight Processing</b>	<b>Room Code:</b>	<b>DPRO-SJ</b>
<b>Net Room Area Briefed</b>	16.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	16.00 M2		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 - 2		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	Area for automatic daylight processing equipment with sorting and viewing of images and films. The processing area should be located with ready access to X-Ray procedure rooms and reporting rooms.		
<b>Amendment</b>	13.03.2014 First issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3085	Wall finish	Tiles	Glazed	Splashback		to sink

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	Sorting and viewing
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset lab sink
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to sorting bench
3350	Clock: battery operated	Furniture/ Fitting	1	1	
4410	Cupboard: under bench	Furniture/ Fitting	1	1	under sink bench, adjustable shelves
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over sink bench, adjustable shelves
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to sink
6156	Dispenser: soap	Furniture/ Fitting	2	1	to sink
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over sorting bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	m	WT	Tap	Dns	Gas	Selection / Remarks
65100	IMG: processor, daylight	3	1	yes	___	yes	___	___	___	yes	yes	___	___	as required
65900	IMG: silver recovery unit	3	1	___	___	___	___	___	___	___	yes	___	___	as required
49115	Sink: 600x450x450D	1	1	___	___	yes	opt	opt	yes	yes	___	___	___	provide hot water; confirm sink dimensions

**Department** | **Standard Components**  
**Room Name** | **Daylight Processing**

**Room Tag:** 2130  
**Room Code:** DPRO-SJ

ID	Description	Group	Qty	Ele	Data	Cd	WH	W/m	WTap	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	on bench
69000	Xray viewer: 6 screen	1	1	yes	___	___	___	___	___	___	___	over bench

**Services**

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	3	1 outlet on sorting bench for telephone
4037	Tundish drain	Hydraulics	1	for processor
6055	Special: task light, built in	Lighting		under O/H shelving
9001	GPO: Double	Power	4	
9060	GPO: Special: for equipment	Power	1	for processor