Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standard Components Laundry - Hospital	Room Tag: Room Code:	2610 LAUN-HO-SJ
Net Room Area Briefed	10.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	10.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 - 2 Staff		
Also covers these Rooms			
Description/ Special Requirements	A small laundry with commercial quality of small items not laundered by an extern include sheep skins and mop heads The laundry tub, commercial small washing n facilities.	nal linen supplier; this may room will include a bench	/ I,
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5021	Ceiling	Plasterboard	Paint, washable	Water resistant, flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		tiles also acceptable
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		Observation window, optional
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or tiled skirting
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset laundry tub
1460	Bracket: wall	Metalwork	1	1	for dryer
1505	Cabinet: ironing board	Furniture/ Fitting	1	1	lockable, with integral ironing board
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench
23956	Trolley: laundry, basket	Furniture/ Fitting	3	1	under bench

Fixtures, Equipment and associated Services (FE)

ID	Description	GroupQty	Ele Data	CdWHtW	VmWTap	Dns	Gas	Selectio	n / Remark	s
		Provided by TAHPI for :			Issue No:	1	F	Print Date:	20 May 201	4
	SHCC Guidelines	Sharjah Domain		le	ssue Date:	1 Apr 2	014		Page 1 of	2

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

	Department Standard Components Room Name Laundry - Hospital									oom ⊺ m Co	0	
ID	Description	Group	Qty	Ele	Data	CdW	HtW	NmW	Тар	Dns	Gas	Selection / Remarks
18200	Dryer: clothes, industrial	3	1	yes								
29200	Iron: electric	3	1	yes								inside cupboard
49400	Sink: laundry, single	1	1			yes	opt	opt	yes	yes		hot water, with overflow drain
60600	Washing machine: industrial	3	1	yes		yes	yes		yes	yes		
Servic	es Description	Servic	e Ca	atego	orv		Qty	Sele	ectior	/ Rei	marks	5
5019	Exhaust	HVAC	•••			,		extra steam/ heat extraction to room				
5037	Special exhaust: dryer	HVAC					1					
5015	Ventilation	HVAC										
4033	Floor waste	Hydrau	ulics				1					

1

3 washer, dryer, ironing cabinet

Lighting

Power

Power

6000

9001

9000

General fluorescent

GPO: Double

GPO: Single