

Department	Standard Components	Room Tag:	2850
Room Name	Lounge - Recovery, Stage 2 (Typical Bay)	Room Code:	LNPT-RS2-SJ
<b>Net Room Area Briefed</b>	6.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	6.00 M2		
<b>Hours of Operation</b>	8am to 6 pm daily		
<b>Occupancy</b>	1 patient, 1 support person, 1 staff assisting		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	<p>The Stage 2 Recovery Lounge may be provided as required to accommodate patients who have regained consciousness after anaesthesia but require further observation or patients recovering from procedures under local anaesthetic. A handwash bay will be located immediately adjacent to this lounge. Separate lounge for male and female may be required.</p> <p>Acoustics: Sound attenuation level - Medium; Acoustic privacy required.</p> <p>Body Protected electrical area</p>		
<b>Amendment</b>	14.03.2014 - First Issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or timber skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin
4045	Wall protection	Timber	Clear finish	Corner guards		to 900 AFFL
7001	Windows					Essential

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	per patient chair
350	Artwork	Furniture/ Fitting	3	1	optional
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	to external windows
1465	Bracket: suction bottle	Furniture/ Fitting	2	3	per patient chair
23410	Bracket: television, wall mount	Metalwork	3	1	for flat screen TV; to be shared in the lounge
2200	Chair: recliner	Furniture/ Fitting	3	1	may include table arm
3350	Clock: battery operated	Furniture/ Fitting	3	1	shared
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	

Department

Standard Components

Room Tag:

2850

Room Name

Lounge - Recovery, Stage 2 (Typical Bay)

Room Code:

LNPT-RS2-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	per patient chair
22000	Suction bottle	Furniture/ Fitting	3	3	per patient chair
22800	Table: low	Furniture/ Fitting	3	2	1 per patient chair; 1 under TV
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

## Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	N	m	W	Tap	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	___	___	___	___	on table, optional; shared by room
3031	Television: flat screen	3	1	yes	___	___	___	___	___	___	___	___	___	___	___	on wall bracket; shared by room

## Services

ID	Description	Service Category	Qty	Selection / Remarks
1090	TV: MATV	Communications	1	
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	per patient chair
7000	Oxygen (O2)	Medical Gases	1	per patient chair
7040	Suction	Medical Gases	3	per patient chair
8080	Emergency call	Nurse Call	1	per room + indicator button & light
8005	Patient call handset	Nurse Call	1	per patient chair; call button on the handset
8000	Patient/ Staff call	Nurse Call	1	per patient chair; + indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	per patient chair; + indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	per room
9010	GPO: Emergency power, single	Power	1	per patient chair
9000	GPO: Single	Power	2	per patient chair + 1 telephone table
9060	GPO: Special: for equipment	Power	1	TV