# Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

Department Room Name	Standard ComponentsRoom Tag:2900Medication/ Treatment Room - Mental HealthRoom Code:MED-MH-S						
Net Room Area Briefed	12.0 M2						
No of Rooms	1						
Subtotal of Briefed Area	12.00 M2						
Hours of Operation	24 Hours						
Occupancy	1 patient with 1-2 support persons; 1 staff						
Also covers these Rooms							
Description/ Special Requirements	The Mental Health Medication/ Treatment Room will provide for administration of medications to patients and private consultation or examination of patients. A second egress door will be required for staff safety and security. All fittings and fixtures to be suitable for mental health patients, fittings should have a breaking strain of not more than 15kg. Acoustics: Sound attenuation level - high; Acoustic privacy essential.						
Amendment	Body Protected electrical area 14.03.2014 - First Issue 24.03.2014 - General revision						

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9006	Doors	Solid Core/ Safety glass	Paint	Single leaf, observation panel		920mm clear opening, staff access
9006	Doors	Solid Core/ Safety glass	Paint	Single leaf, observation panel		1100mm clear opening, patient access; may also have a half height dispensary door, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin & above bench

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	
1470	Bracket: sharps	Furniture/ Fitting	2	1	on trolley
4375	Cupboard: medication, lockable	Furniture/ Fitting	1	1	with drug safe/s

	Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	4	Page 1 of 2

## Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

	Department Room Name	Standard Components Medication/ Treatment Room	- Menta	l Heal	Room Tag: th Room Code:	2900 MED-MH-SJ
ID	Description	Category	Group	Otv	Selection / Pemarks	

ID	Description	Category	Group	Qty	Selection / Remarks
4420	Cupboard: under bench, lockable	Furniture/ Fitting	1	1	adjustable shelves
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelves
4600	Curtain track: bed screen	Metalwork	1	1	to exam couch, ceiling recessed
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
7500	Examination couch	Furniture/ Fitting	3	1	
8100	Footstool	Furniture/ Fitting	3	1	
19060	Safe: dangerous drugs, small	Furniture/ Fitting	1	2	to medication cupboard, to be reinforced for 45 kg weight
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
6600	Trolley: dressing	Furniture/ Fitting	3	1	
18800	Trolley: resuscitation, adult	Furniture/ Fitting	3	1	optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	₩m₩	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B (sim)
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54520	Telephone: handset, handsfree	3	1		yes							to bench
68600	Xray viewer: 1 screen	1	1	yes								

#### Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
8080	Emergency call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	as required
9001	GPO: Double	Power	1	above bench
9001	GPO: Double	Power	1	patient examination area
9000	GPO: Single	Power	2	XRV, fridge (optional)
10005	Duress alarm	Security	1	