## Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

**Room Data Sheets** 

Department Room Name	Standard Components Mould Room - Fitting	Room Tag: Room Code:	3090 MLD-FT-SJ						
Net Room Area Briefed	10.0 M2								
No of Rooms	1								
Subtotal of Briefed Area	10.00 M2								
Hours of Operation	24 Hours								
Occupancy	1 patient; 1 staff								
Also covers these Rooms									
Description/ Special Requirements	The Mould Fitting Room will provide for private examination of patients and fitting of moulds and masks for Radiotherapy Treatments.								
	Acoustics: Sound attenuation level - h	igh; Acoustic privacy essenti	al.						
	Body Protected electrical area								
Amendment	14.03.2014 - First Issue 24.03.2014 - General revision								

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
5007	Ceiling	Plasterboard	Paint	Bulkhead		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		920mm/1400mm clear opening, half door optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	
4410	Cupboard: under bench	Furniture/ Fitting	1	1	
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	
4600	Curtain track: bed screen	Metalwork	1	1	to exam couch
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
	, , , , , , , , , , , , , , , , , , , ,				

 Provided by TAHPI for :
 Issue No: 1
 Print Date:
 20 May 2014

 Sharjah Domain
 Issue Date: 1 Apr 2014
 Page 1 of 2

# Sharjah Healthcare City - Health Facility Guidelines

### **Room Data Sheets**

Milestone: Current

	Department Room Name	Standard Components Mould Room - Fitting		Room Tag: Room Code:	3090 MLD-FT-SJ	
ID	Description	Category	Group	Qty	Selection / Remarks	
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin	
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin	
7500	Examination couch	Furniture/ Fitting	3	1		
8100	Footstool	Furniture/ Fitting	3	1		
13700	Mirror	Metalwork	1	1	for patient changing	
23950	Trolley	Furniture/ Fitting	3	1		
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	<b>V</b> mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		elbow action levers
31701	Light: examination, wall mount	1	1	yes								or ceiling mounted, optional
68700	Xray viewer: 2 screen	1	1	yes								

#### Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	over bench
9001	GPO: Double	Power	2	patient exam couch area
9011	GPO: Emergency power, double	Power	1	patient exam couch area
9060	GPO: Special: for equipment	Power	2	XRV, exam light