

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag:</b>	<b>3110</b>
<b>Room Name</b>	<b>Neonatal Bay - General Care</b>	<b>Room Code:</b>	<b>NBGC-SJ</b>
<b>Net Room Area Briefed</b>	5.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	5.00 M2		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 baby; 1-2 staff		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	A single bay for the care of well babies away from their mother's bed area which may include treatments such as phototherapy. A staff handwash basin should be provided for each four Neonatal Bays - General Care. An external outlook is required.		
	Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls		
	Body Protected electrical area		
<b>Amendment</b>	14.03.2014 - First Issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		
7001	Windows					Essential

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	shared between 4 bays
480	Bassinet	Furniture/ Fitting	3	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	shared between 4 bays
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	shared between 4 bays
22000	Suction bottle	Furniture/ Fitting	3	1	shared between 4 bays

### Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6005	Dimmable	Lighting		variable lighting level

**Department** | **Standard Components**  
**Room Name** | **Neonatal Bay - General Care**

**Room Tag:** 3110  
**Room Code:** NBGC-SJ

ID	Description	Service Category	Qty	Selection / Remarks
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	shared between 4 bays
7000	Oxygen (O2)	Medical Gases	1	shared between 4 bays
7040	Suction	Medical Gases	1	shared between 4 bays
8080	Emergency call	Nurse Call	1	shared between 4 bays
8010	Staff/ Nurse assist call	Nurse Call	1	shared between 4 bays
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	to serve a group of bays
9000	GPO: Single	Power	4	per bay
11000	Wall panel	Services Panels	1	shared between 4 bays