

Department	Standard Components	Room Tag:	3130
Room Name	Neonatal Bay - Special Care	Room Code:	NBSC-SJ
Net Room Area Briefed	10.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	10.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 baby; 1-2 staff; 1-2 parents		
Also covers these Rooms			
Description/ Special Requirements	A single bay for neonates requiring Special Care nursing and medical treatment. The Bay will include provisions for charting and storage. A staff handwash basin (Type A) should be provided within close access of each Bay. An external outlook is required.		
	Acoustics: Sound attenuation level - high; Acoustic privacy is required to perimeter walls		
	Cardiac Protected electrical area		
Amendment	14.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
7001	Windows					External outlook to the area is required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	2	
1050	Bench: laminate	Furniture/ Fitting	1	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	
2655	Chair: visitor	Furniture/ Fitting	3	1	
4430	Cupboard: drawer unit	Furniture/ Fitting	1	2	to each bay; under bench
4410	Cupboard: under bench	Furniture/ Fitting	1	2	to each bay
4600	Curtain track: bed screen	Metalwork	1	1	
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	over bench
22000	Suction bottle	Furniture/ Fitting	3	2	

Department | Standard Components
 Room Name | Neonatal Bay - Special Care

Room Tag: 3130
 Room Code: NBSC-SJ

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	W	m	WTap	Dns	Gas	Selection / Remarks
26000	Humidicrib	3	1	yes	___	___	___	___	___	___	___	___	___	___	or bassinette
31700	Light: examination, ceiling	1	1	yes	___	___	___	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6005	Dimmable	Lighting		variable lighting level
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
7020	Medical Air (MA)	Medical Gases	2	
7000	Oxygen (O2)	Medical Gases	2	
7040	Suction	Medical Gases	2	
8080	Emergency call	Nurse Call	1	
8010	Staff/ Nurse assist call	Nurse Call	1	
9030	Cardiac protected	Power		
9015	GPO: Cleaner	Power	1	to a group of bays
9010	GPO: Emergency power, single	Power	8	
9060	GPO: Special: for equipment	Power	1	exam light
11000	Wall panel	Services Panels	1	flush mounted