

Department	Standard Components	Room Tag:	3340
Room Name	PACS Storage and Viewing	Room Code:	PACS-SJ
Net Room Area Briefed	16.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	16.00 M2		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 4		
Also covers these Rooms			
Description/ Special Requirements	A room located within the Medical Imaging Unit to accommodate the PACS computer equipment along with a workstation area for viewing, and reporting of images.		
Amendment	Acoustics: Sound attenuation level - Medium; acoustic privacy required. 14.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9002	Doors	Solid Core/ Glass	Paint	Single leaf, half glazed		920mm clear opening, glazing optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		vinyl also acceptable
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1120	Bench: workstation	Furniture/ Fitting	1	1	to 2 sides of room
2100	Chair: ergonomic, office	Furniture/ Fitting	3	4	
3350	Clock: battery operated	Furniture/ Fitting	3	1	
17255	Pedestal filing unit: mobile, 660mmH	Furniture/ Fitting	3	2	under bench
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	above bench
20000	Shelving unit: adjustable	Furniture/ Fitting	1	2	over bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	2	under bench
24400	Whiteboard	Furniture/ Fitting	2	1	900x900, optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	m	WTap	Dns	Gas	Selection / Remarks
11415	Computer: PACS	3	2	yes	yes	___	___	___	___	___	___	___	for computerised images
11900	Computer: server	3	1	yes	yes	___	___	___	___	___	___	___	PACS
41100	Printer: networked	3	1	yes	yes	___	___	___	___	___	___	___	

Department | Standard Components
 Room Name | PACS Storage and Viewing

Room Tag: 3340
 Room Code: PACS-SJ

ID	Description	Group	Qty	Ele	Data	Cd	WH	W/m	WTap	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	4		yes							

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	4	1 outlet per workstation for telephone
1006	Voice / Data outlet: double	Communications	1	printer
5000	Airconditioning	HVAC		
6005	Dimmable	Lighting		for image viewing
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H shelving
9001	GPO: Double	Power	9	2 per workstation + 1- printer
9060	GPO: Special: for equipment	Power	1	Server- PACS