Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 3390 Department Room Tag: Patient Bay - Acute Treatment, 12m2 **Room Name Room Code:** PBTR-A12-SJ

Net Room Area Briefed

12.0 M2

No of Rooms

Subtotal of Briefed Area

12.00 M2

Hours of Operation

24 Hours

Occupancy

1 patient; 1 - 2 staff

Also covers these

Special Requirements

Rooms

The Patient Bed Bay Acute Treatment may be used for assessment and treatment of patients with acute conditions and will be located within the Emergency Unit. The Bay may have partition side walls; glazing is recommended. The Patient Bay will have close access to a staff

handwashing basin.

Amendment

Description/

14.03.2014 - First Issue

Body Protected electrical area

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed		to partition walls, if provided
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		As required
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		As required
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

Description	Category	Group	Qty	Selection / Remarks
Air flowmeter	Furniture/ Fitting	3	1	
Bench: laminate, free standing	Furniture/ Fitting	3	1	optional
Blind: Venetian integral	Furniture/ Fitting	1	2	to internal windows if provided
Bracket: monitor	Furniture/ Fitting	3	1	optional, may have ergonomic arm
Bracket: sharps	Furniture/ Fitting	2	1	
Bracket: suction bottle	Furniture/ Fitting	2	2	
Chair: visitor, patient	Furniture/ Fitting	3	1	
Curtain track: bed screen	Metalwork	1	1	
	Air flowmeter Bench: laminate, free standing Blind: Venetian integral Bracket: monitor Bracket: sharps Bracket: suction bottle Chair: visitor, patient	Air flowmeter Furniture/ Fitting Bench: laminate, free standing Furniture/ Fitting Blind: Venetian integral Furniture/ Fitting Bracket: monitor Furniture/ Fitting Bracket: sharps Furniture/ Fitting Bracket: suction bottle Furniture/ Fitting Chair: visitor, patient Furniture/ Fitting	Air flowmeter Furniture/ Fitting 3 Bench: laminate, free standing Furniture/ Fitting 3 Blind: Venetian integral Furniture/ Fitting 1 Bracket: monitor Furniture/ Fitting 3 Bracket: sharps Furniture/ Fitting 2 Bracket: suction bottle Furniture/ Fitting 2 Chair: visitor, patient Furniture/ Fitting 3	Air flowmeter Furniture/ Fitting 3 1 Bench: laminate, free standing Furniture/ Fitting 3 1 Blind: Venetian integral Furniture/ Fitting 1 2 Bracket: monitor Furniture/ Fitting 3 1 Bracket: sharps Furniture/ Fitting 2 1 Bracket: suction bottle Furniture/ Fitting 2 2 Chair: visitor, patient Furniture/ Fitting 3 1

Issue Date: 1 Apr 2014

Sharjah Healthcare City - Health Facility Guidelines

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

Milestone: Current

Department Standard Components Room Tag: 3390
Room Name Patient Bay - Acute Treatment, 12m2 Room Code: PBTR-A12-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
10700	IV hanger for ceiling track	Metalwork	1	1	
11200	IV track: ceiling mounted	Metalwork	1	1	
12900	Louvred panel: for storage-bins	Metalwork	1	2	optional, for storage
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	
19700	Sharps bin	Furniture/ Fitting	3	1	
19800	Shelf: laminate	Furniture/ Fitting	1	1	above services panel, optional
21755	Storage bins	Furniture/ Fitting	3	10	optional, for storage on louvred panel
21950	Suction adapter	Furniture/ Fitting	3	2	
22000	Suction bottle	Furniture/ Fitting	3	2	
23952	Trolley: small	Furniture/ Fitting	3	2	1 trolley under bench

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	%mW	Тар	Dns	Gas	Selection / Remarks
3725	Bed: emergency, electric	3	1	yes								
15900	Diagnostic set: wall mounted	3	1	yes								optional
32150	Light: procedure, ceiling	1	1	yes								
36050	Monitor: cardiac	3	1	yes	opt							optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1120	Monitor connection facilities and cabling	Communications	1	optional, if networked monitoring required
1006	Voice / Data outlet: double	Communications	1	services panel, 1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	services panel
7010	Nitrous Oxide (N2O)	Medical Gases	1	services panel, optional
7000	Oxygen (O2)	Medical Gases	2	services panel
7070	Scavenge	Medical Gases	1	services panel, if N2O provided
7040	Suction	Medical Gases	2	services panel
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	4	services panel, 1 for monitor, if required
9000	GPO: Single	Power	3	services panel
9000	GPO: Single	Power	1	for electric bed
9060	GPO: Special: for equipment	Power	1	procedure light
11000	Wall panel	Services Panels	1	