Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

DepartmentStandard ComponentsRoom Tag:3620Room NamePreparation Room - Non Sterile (Pharmacy)Room Code:PREP-SJ

Net Room Area Briefed

12.0 M2

No of Rooms

1

Subtotal of Briefed Area

12.00 M2

Hours of Operation

24 Hours

Occupancy

Up to 3

Also covers these Rooms

•

Description/

Special Requirements

The Preparation Room provides a wet area for cleaning of equipment and extemporaneous preparation and compounding of medications as required. The Preparation area should be located in close proximity to the Assembly/ Preparation area.

Amendment

14.03.2014 - First Issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		as required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	
4420	Cupboard: under bench, lockable	Furniture/ Fitting	1	1	adjustable shelves
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelves
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	2	to sink & handbasin
6156	Dispenser: soap	Furniture/ Fitting	2	2	to sink & handbasin
23950	Trolley	Furniture/ Fitting	3	2	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	%mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		refer to BHWS-B (sim)
48100	Sink & drainer: R bowl, 930mmL	1	1			yes	opt	opt	yes	yes		hot water
54510	Telephone: handset, standard	3	1		yes							to bench, optional

Services

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Standard Components Room Tag: 3620

Room Name Preparation Room - Non Sterile (Pharmacy) Room Code: PREP-SJ

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9001	GPO: Double	Power	3	