

Department	Standard Components	Room Tag:	3790
Room Name	Scrub Up / Gowning - Shared	Room Code:	SCRBS-SJ
Net Room Area Briefed	10.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	10.00 M2		
Hours of Operation	24 Hours		
Occupancy	Up to 2		
Also covers these Rooms			
Description/ Special Requirements	<p>The Shared Scrub-up Gowning room provides an enclosed area for pre-operative scrubbing and gowning/ gloving, shared between two Operating/ Procedure Rooms.</p> <p>Acoustics: Sound attenuation level - medium; acoustic privacy required</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - A minimum of 800mm is required between scrub stations - Taps to be non touch - automatically operated or foot operated 		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening to Operating Rooms, double swing
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved		to wet zone
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed		to Operating Rooms, optional
7010	Observation	Glass	Clear	Through door/s		with cover, (sliding)
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3010	Wall finish	Paint	Scrub resistant			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		As required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1252	Blind: Venetian integral	Furniture/ Fitting	1	2	to internal windows if provided

Department | Standard Components
 Room Name | Scrub Up / Gowning - Shared

Room Tag: 3790
 Room Code: SCRBS-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6164	Dispenser: scrub brush	Furniture/ Fitting	2	4	
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	4	
12300	Linen carrier: dirty, single	Furniture/ Fitting	3	2	
19800	Shelf: laminate	Furniture/ Fitting	1	2	over linen carriers
19810	Shelf: SS, over	Metalwork	1	2	over scrub trough

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	W	m	WTap	Dns	Gas	Selection / Remarks
9700	Clock: analogue, electric	1	1	yes	___	___	___	___	___	___	___	___	
50000	Sink: scrub trough	1	2	___	___	yes	___	yes	yes	yes	___	___	auto/knee operated taps x 2 each trough

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9000	GPO: Single	Power	1	for clock