# Sharjah Healthcare City - Health Facility Guidelines

**Room Data Sheets** 

Milestone: Current

Department Room Name	Standard Components Shower - Accessible, 4m2	Room Tag: Room Code:	3920 SHD-SJ					
Net Room Area Briefed	4.0 M2							
No of Rooms	1							
Subtotal of Briefed Area	4.00 M2							
Hours of Operation	24 Hours							
Occupancy	1 patient; 1-2 staff assisting as required							
Also covers these Rooms								
Description/ Special Requirements								
	Acoustics: Sound attenuation level - high	; Acoustic privacy required.						
	Body Protected electrical area							
	<ul> <li>Additional Design Considerations:</li> <li>Access is required for commode chairs</li> <li>The floor must not have a raised hob</li> <li>The door will require escape hardware to allow staff access in an emergency</li> </ul>							
Amendment	13.03.2014 - First Issue							

## Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9001	Doors	Solid Core	Paint	Single leaf		920mm clear; Outward opening; privacy latch; emergency release
1175	Floor finish	Tiles	Non-slip	Ceramic		or non-slip studded vinyl
2145	Skirting	Tiles	To match floor	Coved		or coved vinyl skirting
3000	Wall finish	Paint	Acrylic, washable			
3080	Wall finish	Tiles	Glazed	Full height		to wet areas

## Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1002	Bench seat: fold up/down	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 at 1200H for wheelchair users
4800	Curtain track: shower	Metalwork	1	1	
5300	Curtain: shower	Furniture/ Fitting	3	1	

	Provided by TAHPI for :	Issue No: 1	Print Date:	20 May 2014
SHCC Guidelines	Sharjah Domain	Issue Date: 1 Apr 2014	4	Page 1 of 2

# Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

#### **Room Data Sheets**

	Department Room Name	Standard Components Shower - Accessible, 4m2			Room Tag: Room Code:	3920 SHD-SJ
ID	Description	Category	Group	Qty	Selection / Remarks	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1		
8450	Grab rail: Shower	Metalwork	1	1	T bar	
8450	Grab rail: Shower	Metalwork	1	1	L shaped, optional	
20650	Soap/ shampoo holder	Furniture/ Fitting	1	1		
23700	Towel rail	Metalwork	1	1		

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	∕VmW	Тар	Dns	Gas	Selection / Remarks
47400	Shower: hand-held	1	1			yes		yes	yes	yes		

#### Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, water proof
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, water proof