

<b>Department</b>	<b>Standard Components</b>	<b>Room Tag:</b>	<b>3910</b>
<b>Room Name</b>	<b>Shower - Decontamination</b>	<b>Room Code:</b>	<b>SHDEC-SJ</b>
<b>Net Room Area Briefed</b>	8.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	8.00 M2		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 - 2		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	The Decontamination Shower is provided to shower patients who arrive in the Unit contaminated with toxic and/or infectious substances. The room will include a flexible water hose, floor drain and contaminated water trap. The shower should be accessible from the ambulance bay (external) without entering any other part of the Unit. A Personal Protective Equipment Bay may be located in close proximity.		
<b>Amendment</b>	13.03.2014 - First Issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9006	Doors	Solid Core/ Safety glass	Paint	Single leaf, observation panel		920mm clear; Outward opening; privacy latch; emergency release; sliding cover to observation panel
1175	Floor finish	Tiles	Non-slip	Ceramic		
2145	Skirting	Tiles	To match floor	Coved		
3080	Wall finish	Tiles	Glazed	Full height		to wet areas

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	N	m	W	Tap	Dns	Gas	Selection / Remarks
47605	Shower: decontamination	1	2			yes				yes	yes	yes	yes	yes		in lockable cabinets
54520	Telephone: handset, handsfree	3	2		yes											hospital phones, recessed in waterproof lockable cabinets

### Services

ID	Description	Service Category	Qty	Selection / Remarks
1005	Voice / Data outlet: single	Communications	2	for hospital phones

Department

Standard Components

Room Tag:

3910

Room Name

Shower - Decontamination

Room Code:

SHDEC-SJ

ID	Description	Service Category	Qty	Selection / Remarks
5019	Exhaust	HVAC		
5015	Ventilation	HVAC		
4030	Drainage	Hydraulics	1	to contaminated water trap
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	in lockable recess, optional
7000	Oxygen (O2)	Medical Gases	1	in lockable recess, optional
7040	Suction	Medical Gases	1	in lockable recess, optional
8080	Emergency call	Nurse Call	1	
9000	GPO: Single	Power	4	2 to each telephone box, waterproof
11000	Wall panel	Services Panels	1	recessed, lockable cover, if gases required