Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components Department Room Tag: 3930 **Shower - Patient Room Name Room Code:** SHPT-SJ

Net Room Area Briefed

4.0 M2

No of Rooms

Subtotal of Briefed Area

4.00 M2

Hours of Operation

24 Hours

Occupancy

Also covers these Rooms 1 patient; 1-2 staff assisting as required

Description/ **Special Requirements** The Shower - Patient is a room containing a shower and a handbasin for patients in multi-bed rooms to shower or wash, either independently or with nurse assistance.

Acoustics: Sound attenuation level - high; Acoustic privacy required.

Body Protected electrical area

Additional Design Considerations:

- Access is required for commode chairs
- The floor must not have a raised hob
- The door will require escape hardware to allow staff access in an emergency

Amendment

13.03.2014 - First Issue 24.03.2014 - General revision

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9001	Doors	Solid Core	Paint	Single leaf		920mm clear; outward opening; privacy latch; emergency release
1175	Floor finish	Tiles	Non-slip	Ceramic		
2145	Skirting	Tiles	To match floor	Coved		
3000	Wall finish	Paint	Acrylic, washable			
3080	Wall finish	Tiles	Glazed	Full height		to wet areas

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 @ 1200H for wheelchair users
4800	Curtain track: shower	Metalwork	1	1	

Issue Date: 1 Apr 2014

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

DepartmentStandard ComponentsRoom Tag:3930Room NameShower - PatientRoom Code:SHPT-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
5300	Curtain: shower	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
8450	Grab rail: Shower	Metalwork	1	1	
9200	Hook: for catheter bag	Metalwork	1	1	
10800	Hook: for IV flasks	Metalwork	1	1	
13700	Mirror	Metalwork	1	1	
20650	Soap/ shampoo holder	Furniture/ Fitting	1	1	
23700	Towel rail	Metalwork	1	1	with grab rail strength/ fixings
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	%mW	Тар	Dns	Gas	Selection / Remarks
3120	Basin: vanity	1	1			yes		yes	yes	yes		
47400	Shower: hand-held	1	1			yes		yes	yes	yes		

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light, waterproof
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, waterproof
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, waterproof
9040	Body protected	Power		
9001	GPO: Double	Power	1	locate near door outside room
9000	GPO: Single	Power	1	for hair dryer & shaver use only; to comply with relevant electric safety guidelines