Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 1 of 1

Issue No: 1

Issue Date: 1 Apr 2014

DepartmentStandard ComponentsRoom Tag:4330Room NameStore - Flammable LiquidRoom Code:STFL-SJ

Net Room Area Briefed

9.0 M2

No of Rooms

•

Subtotal of Briefed Area

9.00 M2

Hours of Operation

24 Hours

Occupancy

- 1 1 10010

Also covers these Rooms

1 intermittently

Description/ Special Requirements The Flammable Liquid Store is a fire-rated room for the storage of flammable liquids, to comply with relevant standards for the storage and handling of flammable and combustibe liquids.

Additional Design Requirements:

- Walls and door to be constructed of fire rated materials
- The floor will require bunding to contain spillage
- The door will be outward opening
- The room will require provisions for fire and smoke detection

Amendment

13.03.2014 - First Issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5140	Ceiling	Concrete	Paint	Acrylic		
9001	Doors	Solid Core	Paint	Single leaf		920mm clear opening, lockable, fire rated, outward opening
1280	Floor finish	Concrete	Trowel	Sealed		
2155	Skirting	Concrete	Sealed	Coved concrete to 150 AFFL		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

IE	כ	Description	Category	Group	Qty	Selection / Remarks
13	3660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	7	heavy duty

Services

ID	Description	Service Category	Qty	Selection / Remarks
3018	Heat Detector	Fire Services		
3000	Smoke detectors	Fire Services		
5019	Exhaust	HVAC		
5015	Ventilation	HVAC		
6135	Special: hazardous location	Lighting		switch outside the room