Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department Room Name	Standard Components Store - Sterile Stock, 12m2	Room Tag: Room Code:	4520 STSS-12-SJ					
Net Room Area Briefed	12.0 M2							
No of Rooms	1							
Subtotal of Briefed Area	12.00 M2							
Hours of Operation	24 Hours							
Occupancy	1 - 2 intermittently							
Also covers these Rooms								
Description/ Special Requirements	A room with an aseptic environment for storage and holding of sterile stock for use in the Operating Suite or other treatment areas. This area may also accommodate drugs in lockable cupboards and safe as required.							
Amendment	13.03.2014 - First Issue 24.03.2014 - General revision							

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5020	Ceiling	Plasterboard	Paint, scrub resistant	Flush set, suspended		
6015	Cornice	Plasterboard	Paint	Flush coved between wall & ceiling		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3010	Wall finish	Paint	Scrub resistant			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	optional
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to bench, if provided
3350	Clock: battery operated	Furniture/ Fitting	3	1	
4375	Cupboard: medication, lockable	Furniture/ Fitting	1	1	with drug safe, optional
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, optional
19060	Safe: dangerous drugs, small	Furniture/ Fitting	1	1	optional, to be reinforced for 45 kg weight
20020	Shelving: stainless steel wire mesh	Furniture/ Fitting	3	6	-
10200	Trolley: instrument	Furniture/ Fitting	3	1	
24400	Whiteboard	Furniture/ Fitting	2	1	optional

 Provided by TAHPI for :
 Issue No: 1
 Print Date:
 20 May 2014

 Sharjah Domain
 Issue Date: 1 Apr 2014
 Page 1 of 2

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Department	Standard Components	Room Tag:	4520
Room Name	Store - Sterile Stock, 12m2	Room Code:	STSS-12-SJ

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	₩m₩	Тар	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1		yes							to bench, optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5005	Air conditioning: special	HVAC		HEPA filtered
5040	Pressure: positive	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards if provided
9001	GPO: Double	Power	2	