

Department	Standard Components	Room Tag:	4570
Room Name	Stress Testing	Room Code:	STRT-SJ
<b>Net Room Area Briefed</b>	12.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	12.00 M2		
<b>Hours of Operation</b>	Available 24 Hours		
<b>Occupancy</b>	1 patient; 1 - 2 staff		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	Room for undertaking patient diagnostic stress testing procedures. The Stress Testing room should be located close to patient toilet and change rooms.		
	Acoustics: Acoustic privacy required		
	Body Protected electrical area		
<b>Amendment</b>	13.03.2014 - First Issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin; tiles also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1650	Chair: client	Furniture/ Fitting	3	1	
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
3350	Clock: battery operated	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	1	
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin

Department | Standard Components  
 Room Name | Stress Testing

Room Tag: 4570  
 Room Code: STRT-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
7520	Exercise bicycle	Furniture/ Fitting	3	1	
22615	Table: computer	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	W	m	WT	ap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	___	___	refer to BHWS-B (sim)
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	___	___	___	___	to computer table
56600	Treadmill: automatic	3	1	yes	___	___	___	___	___	___	___	___	___	___	___	

### Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	2	call button on the handset
8000	Patient/ Staff call	Nurse Call	2	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	4	