

Department	Standard Components	Room Tag:	4590
Room Name	Toilet - Patient	Room Code:	WCPT-SJ
Net Room Area Briefed	4.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	4.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1 staff assisting as required		
Also covers these Rooms			
Description/ Special Requirements	Room containing a toilet and handbasin for patients in multi-bed rooms or adjacent to communal patient areas. The door will be fitted with escape hardware to allow staff access in an emergency.		
	Acoustics: Sound attenuation level - High. Acoustic privacy required.		
	Body protected electrical area		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		both sides
8040	Door protection	Composite	Prefinished PVC	To door frame		both sides
9001	Doors	Solid Core	Paint	Single leaf		920mm clear outward opening, privacy latch, emergency release
1175	Floor finish	Tiles	Non-slip	Ceramic		or non-slip vinyl flooring
2145	Skirting	Tiles	To match floor	Coved		or coved vinyl skirting
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
530	Basin vanity top	Furniture/ Fitting	1	1	
3400	Coathook	Metalwork	1	2	1 @ 1200 AFFL for wheelchair users
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	optional
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6160	Dispenser: toilet paper	Furniture/ Fitting	1	1	
8400	Grab rail: WC	Metalwork	1	2	1 behind toilet, 1 to side
8500	Grab rail: WC, hinged	Metalwork	1	1	optional, drop down rail
9200	Hook: for catheter bag	Metalwork	1	1	
10800	Hook: for IV flasks	Metalwork	1	1	

Department | Standard Components
 Room Name | Toilet - Patient

Room Tag: 4590
 Room Code: WCPT-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
13700	Mirror	Metalwork	1	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	T	W	m	WT	Tap	Dns	Gas	Selection / Remarks
3120	Basin: vanity	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	___	
3003	Bidet handset	1	1	___	___	___	___	yes	yes	___	___	___	___	___	
55605	Toilet suite: patient	1	1	___	___	yes	___	___	yes	yes	yes	___	___	___	

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	locate near door outside room