

Department	Standard Components	Room Tag:	4670
Room Name	Treatment Room - Secure Assessment	Room Code:	TRSA-SJ
Net Room Area Briefed	14.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	14.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1 - 2 staff		
Also covers these Rooms			
Description/ Special Requirements	<p>The Treatment Room - Secure Assessment provides a controlled environment, privacy and facilities for assessment and treatment of patients with acute conditions, suitable for mental health patients, and will be located within the Emergency Unit; Services will be enclosed for mental health patient use. The room will have close access to a staff handwashing basin.</p> <p>Acoustics: Sound attenuation level - high; Acoustic privacy is required.</p> <p>Body Protected electrical area</p>		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8040	Door protection	Composite	Prefinished PVC	To door frame		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900AFFL		
9006	Doors	Solid Core/ Safety glass	Paint	Single leaf, observation panel		850mm clear opening, with integral venetians, staff access
9127	Doors	Solid Core/ Safety glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening, with integral venetians
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7055	Observation	Alum/ Glass	Powdercoat	Internal window, double glazed		safety glass with integral venetians
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	to services panel

Department

Standard Components

Room Tag:

4670

Room Name

Treatment Room - Secure Assessment

Room Code:

TRSA-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
1252	Blind: Venetian integral	Furniture/ Fitting	1	3	to observation window & door glazing, controls outside room
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	to services panel
21950	Suction adapter	Furniture/ Fitting	3	1	to services panel
22000	Suction bottle	Furniture/ Fitting	3	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	W	/m	W	Tap	Dns	Gas	Selection / Remarks
3700	Bed: inpatient, electric	3	1	yes	___	___	___	___	___	___	___	___	___	___	___	
15900	Diagnostic set: wall mounted	3	1	yes	___	___	___	___	___	___	___	___	___	___	___	optional, behind roller shutter
45575	Roller shutter: automatic	1	1	yes	___	___	___	___	___	___	___	___	___	___	___	enclosing bedhead services

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	services panel, 1 outlet for telephone
5000	Airconditioning	HVAC		
6032	Downlights: colour corrected	Lighting	1	over bed
6110	Downlights: dimmable	Lighting		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	services panel
7000	Oxygen (O2)	Medical Gases	1	services panel
7040	Suction	Medical Gases	1	services panel
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9010	GPO: Emergency power, single	Power	4	services panel, 1 for monitor, if required
9000	GPO: Single	Power	3	services panel
10005	Duress alarm	Security	2	1 each side of room
11000	Wall panel	Services Panels	1	recessed