

Department	Standard Components	Room Tag:	4890
Room Name	X-ray Viewing and Reporting	Room Code:	XRRR-SJ
Net Room Area Briefed	12.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	12.00 M2		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 4		
Also covers these Rooms			
Description/ Special Requirements	Room within a Clinical or Diagnostic Unit for reviewing and reporting of patient imaging film or computerised images and to write reports.		
	Acoustics: Sound attenuation - medium; Acoustic privacy is required		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high		
9002	Doors	Solid Core/ Glass	Paint	Single leaf, half glazed		920mm clear opening, glazing optional
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		vinyl also acceptable
7010	Observation	Glass	Clear	Through door/s		
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1120	Bench: workstation	Furniture/ Fitting	1	1	to 2 sides of room
2100	Chair: ergonomic, office	Furniture/ Fitting	3	4	
3350	Clock: battery operated	Furniture/ Fitting	3	1	
17255	Pedestal filing unit: mobile, 660mmH	Furniture/ Fitting	3	2	under bench
17310	Pigeon-hole unit	Furniture/ Fitting	1	2	above bench, vertical slots for X-Rays
17360	Pinboard: fabric covered	Furniture/ Fitting	1	2	above bench
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	2	under bench
24400	Whiteboard	Furniture/ Fitting	2	1	900x900, optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	Wh	TW	Nm	WTap	Dns	Gas	Selection / Remarks
11415	Computer: PACS	3	2	yes	yes	___	___	___	___	___	___	___	for computerised images
41100	Printer: networked	3	1	yes	yes	___	___	___	___	___	___	___	

Department | **Standard Components**
Room Name | **X-ray Viewing and Reporting**

Room Tag: 4890
Room Code: XRRR-SJ

ID	Description	Group	Qty	Ele	Data	Cd	WH	W/m	WTap	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	4		yes							
69210	Xray viewer: multiscreen	3	2	yes								optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	4	1 outlet per workstation for telephone
1006	Voice / Data outlet: double	Communications	1	printer
5000	Airconditioning	HVAC		
6005	Dimmable	Lighting		for image viewing
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting	1	under O/H shelving
9001	GPO: Double	Power	9	2 per workstation + 1- printer
9060	GPO: Special: for equipment	Power	2	X-ray viewers (optional)