

Department	Standard Components	Room Tag:	1110
Room Name	ADL Bathroom	Room Code:	ADLB-SJ
<b>Net Room Area Briefed</b>	12.0 M2		
<b>No of Rooms</b>	1		
<b>Subtotal of Briefed Area</b>	12.00 M2		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>	1 patient; 1 - 2 staff		
<b>Also covers these Rooms</b>			
<b>Description/ Special Requirements</b>	<p>A bathroom for patient 'Activities of Daily Living' assessment and training. The ADL Bathroom provides for training of patients to use a domestic bath, patient dressing, undressing, grooming and handwashing. Facilities include a domestic bath installed in a corner of the room, accessible toilet and handbasin and a separate shower within the room. A low height adjustable shower is required over the bath.</p> <p>Additional Design Requirements:</p> <ul style="list-style-type: none"> <li>- The shower area must not have a raised hob.</li> <li>- The entrance to the bathroom is to be flush with the adjoining corridor.</li> </ul> <p>Acoustics: Sound attenuation level - Medium. Acoustic privacy required.</p> <p>Body Protected electrical area</p>		
<b>Amendment</b>	13.03.2014 First issue		

### Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9110	Doors	Solid Core	Paint	1 1/2 leaf		1400mm clear opening, privacy latch
1175	Floor finish	Tiles	Non-slip	Ceramic		non-slip vinyl also acceptable
2145	Skirting	Tiles	To match floor	Coved		or coved vinyl skirting for vinyl floor
3080	Wall finish	Tiles	Glazed	Full height		wall vinyl also acceptable

### Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1002	Bench seat: fold up/down	Furniture/ Fitting	1	1	in shower area; shower chair also acceptable
2300	Chair: shower	Furniture/ Fitting	3	1	
3400	Coathook	Metalwork	1	2	1 at 1000H

Department  
Room Name

Standard Components  
ADL Bathroom

Room Tag: 1110  
Room Code: ADLB-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
4700	Curtain track: privacy screen	Metalwork	1	1	to entry door
4800	Curtain track: shower	Metalwork	1	1	
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to entry door
5300	Curtain: shower	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	near entry
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6160	Dispenser: toilet paper	Furniture/ Fitting	2	2	to toilet grab rails
8430	Grab rail: Bath	Metalwork	1	2	
8450	Grab rail: Shower	Metalwork	1	1	
8420	Grab rail: WC, disabled use	Metalwork	1	1	
13700	Mirror	Metalwork	1	1	above basin
13800	Mirror: full length	Metalwork	1	1	dressing
19800	Shelf: laminate	Furniture/ Fitting	1	2	150mmW x 400mmL; vanity; 1 near bath, 1 near basin
20650	Soap/ shampoo holder	Furniture/ Fitting	1	2	
23700	Towel rail	Metalwork	1	1	
23865	Transfer bench	Furniture/ Fitting	3	1	portable - not fixed, near bath

### Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	T	m	WT	Tap	Dns	Gas	Selection / Remarks
3050	Basin: handwash, disabled	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	lever taps
3201	Bath: domestic	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	
3003	Bidet handset	1	1	___	___	___	___	yes	yes	___	___	___	___	near toilet
47400	Shower: hand-held	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	
47400	Shower: hand-held	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	low level over bath
55650	Toilet suite: disabled use	1	1	___	___	yes	___	___	yes	yes	yes	___	___	with backrest

### Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	2	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	3	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	2	+ indicator button & light
9040	Body protected	Power		
9001	GPO: Double	Power	1	locate near door outside room
9060	GPO: Special: for equipment	Power	1	for hair dryer & shaver use only; to comply with relevant electric safety guidelines