

Department	Standard Components	Room Tag:	1180
Room Name	After Hours Blood Fridge	Room Code:	AHBBF-SJ
Net Room Area Briefed	3.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	3.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 - 2 intermittently		
Also covers these Rooms			
Description/ Special Requirements	The After Hours Blood Fridge is a discreet area for refrigerated storage of blood and blood products for after hours access by authorised personnel. The After Hours Blood Fridge may be located in close proximity to a Critical Care Unit.		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500AFFL		As required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	for recording
17385	Pinboard/ whiteboard combination	Furniture/ Fitting	2	1	combination unit

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	W	H	T	W	m	W	Tap	Dns	Gas	Selection / Remarks
21805	Freezer: blood products	3	1	yes	opt	___	___	___	___	___	___	___	___	___	___	with temperature alarm, optional
44300	Refrigerator: blood products	3	1	yes	opt	___	___	___	___	___	___	___	___	___	___	with temperature alarm

Services

ID	Description	Service Category	Qty	Selection / Remarks
1085	Temperature monitor & alarm	Communications	2	1 to each blood fridge/ freezer
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9011	GPO: Emergency power, double	Power	2	1 to each blood fridge/ freezer