

Department	Standard Components	Room Tag:	1230
Room Name	Ambulance Triage	Room Code:	AMBTR-SJ
Net Room Area Briefed	12.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	12.00 M2		
Hours of Operation	24 Hours		
Occupancy	Up to 3		
Also covers these Rooms			
Description/ Special Requirements	The Ambulance Triage is an area for receipt and assessment of patients arriving in the Unit by ambulance. The Ambulance Triage will be adjacent to the Ambulance entry which should include an Airlock.		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin, tiles also acceptable
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900 AFFL		As required
3092	Wall protection	MDF	Laminate	Bed protection wall panel		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	optional
1110	Bench: laminate, writing	Furniture/ Fitting	1	1	ambulance write-up
1252	Blind: Venetian integral	Furniture/ Fitting	1	1	if internal window provided
1465	Bracket: suction bottle	Furniture/ Fitting	2	2	optional
3350	Clock: battery operated	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	optional

Department | Standard Components
 Room Name | Ambulance Triage

Room Tag: 1230
 Room Code: AMBTR-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
19800	Shelf: laminate	Furniture/ Fitting	1	1	to head of trolleys
22000	Suction bottle	Furniture/ Fitting	3	2	optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	T	m	W	Tap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	___	___	wall telephone

Services

ID	Description	Service Category	Qty	Selection / Remarks
1000	Telephone: PABX	Communications	1	wall telephone
1006	Voice / Data outlet: double	Communications	3	1 to write-up bench
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	optional
7000	Oxygen (O2)	Medical Gases	2	optional
7040	Suction	Medical Gases	2	optional
8080	Emergency call	Nurse Call	1	
8010	Staff/ Nurse assist call	Nurse Call	1	
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	to write-up bench
9010	GPO: Emergency power, single	Power	2	
9000	GPO: Single	Power	2	