

Department	Standard Components	Room Tag:	2050
Room Name	Consult Room - ENT/ Ophthalmology	Room Code:	CONS-ENT-OPT-SJ
Net Room Area Briefed	14.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	14.00 M2		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 staff and on occasions an escort/ interpreter		
Also covers these Rooms			
Description/ Special Requirements	The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations.		
	Acoustics: Sound attenuation level - high; Acoustic privacy essential.		
	Body Protected electrical area		
Amendment	13.03.2014 First issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		flush ser plasterboard ceiling also acceptable
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable; observation panel optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		Carpet also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or timber skirting over carpet
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	optional
1470	Bracket: sharps	Furniture/ Fitting	2	1	
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	optional
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	
2600	Chair: visitor, office	Furniture/ Fitting	3	3	
3400	Coathook	Metalwork	1	2	

Department

Standard Components

Room Tag:

2050

Room Name

Consult Room - ENT/ Ophthalmology

Room Code:CONS-ENT-OPT-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
4600	Curtain track: bed screen	Metalwork	1	1	to exam couch
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
5900	Desk	Furniture/ Fitting	3	1	
6140	Diagnostic set: portable	Furniture/ Fitting	3	1	optional
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
7500	Examination couch	Furniture/ Fitting	3	1	
8100	Footstool	Furniture/ Fitting	3	1	
13725	Mirror: hinged	Metalwork	3	1	wall mounted, for eye chart
16250	Oxygen flowmeter	Furniture/ Fitting	3	1	optional
19700	Sharps bin	Furniture/ Fitting	3	1	Wall mounted
21030	Sphygmomanometer: wall mounted	Furniture/ Fitting	3	1	
21950	Suction adapter	Furniture/ Fitting	3	1	optional
22000	Suction bottle	Furniture/ Fitting	3	1	optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	TW	m	WT	Tap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1	___	___	yes	___	yes	yes	yes	yes	___	___	refer to BHWS-B (sim)
36910	Light box: optical	3	1	yes	___	___	___	___	___	___	___	___	___	Snellen eye chart light box
31701	Light: examination, wall mount	1	1	yes	___	___	___	___	___	___	___	___	___	or ceiling mounted, optional
44360	Refrigerator: drugs, small	3	1	yes	opt	___	___	___	___	___	___	___	___	eye medications
50600	Slit lamp	3	1	yes	___	___	___	___	___	___	___	___	___	
54520	Telephone: handset, handsfree	3	1	___	yes	___	___	___	___	___	___	___	___	to desk
68700	Xray viewer: 2 screen	1	1	yes	___	___	___	___	___	___	___	___	___	

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
7020	Medical Air (MA)	Medical Gases	1	optional
7000	Oxygen (O2)	Medical Gases	1	optional
7040	Suction	Medical Gases	1	optional
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	as required
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	patient examination area
9001	GPO: Double	Power	2	workstation / desk area

Department

Standard Components

Room Tag:

2050

Room Name

Consult Room - ENT/ Ophthalmology

Room Code:CONS-ENT-OPT-SJ

ID	Description	Service Category	Qty	Selection / Remarks
9011	GPO: Emergency power, double	Power	1	patient examination area
9000	GPO: Single	Power	5	Fridge, XRV, light box, slit lamp; 1 to exam couch (optional)
9060	GPO: Special: for equipment	Power	1	exam light
10005	Duress alarm	Security	1	