Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 2810 Department Room Tag: Lounge - Patient, 15m2 **Room Name Room Code:** LNPT-15-SJ

Net Room Area Briefed

15.0 M2

No of Rooms

Subtotal of Briefed Area

15.00 M2

Hours of Operation

24 Hours

Occupancy

Up to 10 patients/ visitors; 1-2 staff intermittently

Also covers these Rooms

Description/ **Special Requirements**

The Patient Lounge provides a change of environment away from clinical areas for patients and visitors. It is an area where family groups can visit and patients can socialise. An external outlook is essential.

Acoustics: Sound attenuation level - Medium; Acoustic privacy required.

Body Protected electrical area

Amendment

14.03.2014 - First Issue 24.03.2014 - General revision

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9115	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, half glazed		1400mm clear opening
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.		Vinyl also acceptable
7030	Observation	Alum/ Glass	Powdercoat	Internal window, door height		optional
949496	Skirting	Timber	Paint	150mmH x 20mm thick, nominal		or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable			
7001	Windows					essential

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks			
350	Artwork	Furniture/ Fitting	3	2	optional			
1300	Bookcase	Furniture/ Fitting	3	1	optional			
23410	Bracket: television, wall mount	Metalwork	3	1	optional			
2000	Chair: lounge	Furniture/ Fitting	3	6	for patients			
4900	Curtain track: window	Metalwork	1	1				
5410	Curtain: window, drapes	Furniture/ Fitting	3	1	or blinds			
22800	Table: low	Furniture/ Fitting	3	3				

Sharjah Healthcare City - Health Facility Guidelines

Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

Department Room Name

Standard Components Lounge - Patient, 15m2 Room Tag: Room Code: 2810 LNPT-15-SJ

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	∕/mW	Тар	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1		yes							on table, optional
3031	Television: flat screen	3	1	yes								on bracket, optional

Services

Description	Service Category	Qty	Selection / Remarks				
TV: MATV	Communications	1	optional				
Voice / Data outlet: double	Communications	1	1 outlet for telephone				
Airconditioning	HVAC						
General fluorescent	Lighting						
Indirect lighting	Lighting		optional				
Emergency call	Nurse Call	1	+ indicator button & light				
Patient call handset	Nurse Call	1	call button on the handset				
Patient/ Staff call	Nurse Call	1	+ indicator button & light				
Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light				
Body protected	Power						
GPO: Cleaner	Power	1					
GPO: Single	Power	6					
GPO: Special: for equipment	Power	1	TV, optional				
	TV: MATV Voice / Data outlet: double Airconditioning General fluorescent Indirect lighting Emergency call Patient call handset Patient/ Staff call Staff/ Nurse assist call Body protected GPO: Cleaner GPO: Single	TV: MATV Voice / Data outlet: double Airconditioning HVAC General fluorescent Indirect lighting Emergency call Patient call handset Patient/ Staff call Staff/ Nurse assist call Body protected GPO: Cleaner GPO: Single Communications Communications Communications Communications Aurse Call Lighting Lighting Nurse Call Nurse Call Nurse Call Power Power	TV: MATV Communications 1 Voice / Data outlet: double Communications 1 Airconditioning HVAC General fluorescent Lighting Indirect lighting Lighting Emergency call Nurse Call 1 Patient call handset Nurse Call 1 Patient/ Staff call Nurse Call 1 Staff/ Nurse assist call Nurse Call 1 Body protected Power GPO: Cleaner Power 1 GPO: Single Power 6				