

Department	Standard Components	Room Tag:	2880
Room Name	Mammography	Room Code:	MAMMO-SJ
Net Room Area Briefed	16.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	16.00 M2		
Hours of Operation	Available 24 Hours		
Occupancy	1 patient; Up to 2 staff assisting		
Also covers these Rooms			
Description/ Special Requirements	<p>X-ray room for mammography imaging procedures, with change area within the room.</p> <p>Acoustics: Acoustic privacy required</p> <p>Body Protected electrical area</p> <p>Additional Design Considerations:</p> <ul style="list-style-type: none"> - Radiation shielding as advised by Radiation Consultant - Cable ducts between X-ray table and control area may be required - 'X-ray in Use' lights required outside each entry door 		
Amendment	<p>14.03.2014 - First Issue</p> <p>24.03.2014 - General revision</p>		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200		
5007	Ceiling	Plasterboard	Paint	Bulkhead		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9130	Doors	Solid Core	Paint	1 1/2 leaf, with lead shielding		1400mm clear opening
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3022	Wall finish	Resinate, 6mm	Prefinished	Splashback		to basin

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1650	Chair: client	Furniture/ Fitting	3	1	to change area
2100	Chair: ergonomic, office	Furniture/ Fitting	3	1	to desk
2055	Chair: mammography	Furniture/ Fitting	3	1	

Department | Standard Components
Room Name | Mammography

Room Tag: 2880
Room Code: MAMMO-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
3400	Coathook	Metalwork	1	2	to change area, 1 @1200H
4350	Cupboard: tall	Furniture/ Fitting	1	1	adjustable shelves
4700	Curtain track: privacy screen	Metalwork	1	1	to change area
5250	Curtain: privacy screen	Furniture/ Fitting	3	1	to change area
5900	Desk	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
13700	Mirror	Metalwork	1	1	to change area
20000	Shelving unit: adjustable	Furniture/ Fitting	1	1	above desk, optional
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	T	m	WTap	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes			refer to BHWS-B (sim)
66700	IMG: Mammography imaging unit	1	1	yes	yes								with control panel
54510	Telephone: handset, standard	3	1		yes								to desk
68700	Xray viewer: 2 screen	1	1	yes									above desk

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	to desk, 1 outlet for telephone
5000	Airconditioning	HVAC		
6110	Downlights: dimmable	Lighting		
6001	General: colour corrected	Lighting		
8080	Emergency call	Nurse Call	1	
8010	Staff/ Nurse assist call	Nurse Call	1	
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	3	2 to desk area
9010	GPO: Emergency power, single	Power	2	
9000	GPO: Single	Power	1	x-ray viewer
9060	GPO: Special: for equipment	Power	1	Mammography unit
12030	Lead lining	Shielding		to walls and doors as specified