Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Standard Components 3630 **Department** Room Tag: Preparation/ Set-up Room (Imaging) **Room Name Room Code:** PREP-S-SJ

Net Room Area Briefed

9.0 M2

No of Rooms

Subtotal of Briefed Area

9.00 M2

Hours of Operation

24 Hours

Occupancy

1 - 2 intermittently

Also covers these Rooms

Description/ **Special Requirements** A room for the storage and preparation of radiological media used in imaging procedures, and where set-up for procedures is undertaken.

Amendment

14.03.2014 - First Issue

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6025	Cornice	Aluminium	Powdercoat	shadow line		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		
8040	Door protection	Composite	Prefinished PVC	To door frame		
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		920mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500AFFL		tiles also acceptable
3060	Wall finish	Vinyl	Prefinished	Splashback		tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1050	Bench: laminate	Furniture/ Fitting	1	1	with inset sink
1470	Bracket: sharps	Furniture/ Fitting	2	1	
4360	Cupboard: door ht adj. shelves	Furniture/ Fitting	1	1	lockable
4410	Cupboard: under bench	Furniture/ Fitting	1	1	with adjustable shelf
4470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, with adjustable shelf
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
6154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to hand basin
6156	Dispenser: soap	Furniture/ Fitting	2	1	to hand basin
6158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to hand basin
12900	Louvred panel: for storage-bins	Metalwork	1	2	above bench, optional

Issue Date: 1 Apr 2014

Sharjah Healthcare City - Health Facility Guidelines Milestone: Current

Room Data Sheets

Print Date: 20 May 2014

Page 2 of 2

Issue No: 1

Issue Date: 1 Apr 2014

DepartmentStandard ComponentsRoom Tag:3630Room NamePreparation/ Set-up Room (Imaging)Room Code:PREP-S-SJ

ID	Description	Category	Group	Qty	Selection / Remarks
19700	Sharps bin	Furniture/ Fitting	3	1	
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to hand basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	//mW	Тар	Dns	Gas	Selection / Remarks
2800	Basin: handwash, Type B	1	1			yes		yes	yes	yes		
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
47900	Sink & drainer: L bowl, 930mmL	1	1			yes	opt	opt	yes	yes		hot water
54510	Telephone: handset, standard	3	1		yes							optional, on bench

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
9000	GPO: Single	Power	1	Refrigerator, under bench
9000	GPO: Single	Power	4	