

Department	Standard Components	Room Tag:	4530
Room Name	Store - Sterile Stock, 20m2 (CSSU)	Room Code:	STSS-20-SJ
Net Room Area Briefed	20.0 M2		
No of Rooms	1		
Subtotal of Briefed Area	20.00 M2		
Hours of Operation	8am to 8 pm daily		
Occupancy	Up to 3 intermittently		
Also covers these Rooms			
Description/ Special Requirements	An area for storage and holding of sterile stock within the Sterile Supply Unit prior to despatch to the Operating Unit or other patient treatment areas. The area may include a workstation bench as required.		
Amendment	13.03.2014 - First Issue		

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5020	Ceiling	Plasterboard	Paint, scrub resistant	Flush set, suspended		
6015	Cornice	Plasterboard	Paint	Flush covered between wall & ceiling		
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3010	Wall finish	Paint	Scrub resistant			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1120	Bench: workstation	Furniture/ Fitting	1	1	optional, at 900mm AFFL
1950	Chair: ergonomic, high	Furniture/ Fitting	3	1	to bench, if provided
3350	Clock: battery operated	Furniture/ Fitting	3	1	
4460	Cupboard: wall mounted	Furniture/ Fitting	1	1	over bench, optional
19940	Shelving: stainless steel, mobile	Furniture/ Fitting	3	10	dust free
10200	Trolley: instrument	Furniture/ Fitting	3	2	
24400	Whiteboard	Furniture/ Fitting	2	1	optional

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	Cd	WH	T	m	W	Tap	Dns	Gas	Selection / Remarks
54510	Telephone: handset, standard	3	1	___	yes	___	___	___	___	___	___	___	___	to bench, optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
----	-------------	------------------	-----	---------------------

Department | **Standard Components** | **Room Tag:** 4530
Room Name | **Store - Sterile Stock, 20m2 (CSSU)** | **Room Code:** STSS-20-SJ

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5005	Air conditioning: special	HVAC		HEPA filtered
5040	Pressure: positive	HVAC		
6000	General fluorescent	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards, if provided
9001	GPO: Double	Power	2	to workstation