

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **ADL Kitchen**

Room Code **ADLK**

Area M2 12

Description A Domestic style kitchen for patient Activities of Daily Living assessment and training; bench is to be wheelchair accessible.
Special Requirement Body Protected electrical area

Room Fabric and outline specifications

Remarks

1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150mmH	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	tiles also acceptable
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7010	Observation	Glass	Clear	Through door/s	
7035	Observation	Alum/ glass	Powdercoat	Internal window	optional
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9013	Doors	Solid Core	Paint	1 1/2 leaf, observation panel	Optional, 1350mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
1050	Furniture/ Fitting	Bench: laminate	1	1	with inset sink, open under part
4440	Furniture/ Fitting	Cupboard: drawer unit, lockable	1	2	under bench
4470	Furniture/ Fitting	Cupboard: wall mounted, lockable	1	1	over bench
6154	Furniture/ Fitting	Dispenser: paper towel	2	1	to sink
6156	Furniture/ Fitting	Dispenser: soap	2	1	to sink

Fixtures, Equipment and associated services

FFE ID	Description	Grp	Quant	Ele	CdW	HtW	WmW	Tap	Dns	Gas	Stm	Selection
5000	Boiling water unit	1	1	yes	yes	___	___	yes	yes	___	___	optional
42950	Range hood	1	1	yes	___	___	___	___	___	___	___	over stove
48300	Sink & drainer 1 1/2 bowls	1	1	___	yes	___	yes	yes	yes	___	___	
53010	Stove : electric , domestic	1	1	yes	___	___	___	___	___	___	___	

Services

Service ID	Service Category	Description	Quantity	Remarks
3000	Fire Services	Smoke detectors		as required
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
5019	HVAC	Exhaust	1	to rangehood
6000	Lighting	General		
9000	Power	GPO: Single	3	benchtop

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **ADL Kitchen**

Room Code **ADLK**

Service ID	Service Category	Description	Quantity	Remarks
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	3	BWU, Microwave, fridge
9060	Power	Special: for equipment	2	stove, rangehood