

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name Lounge - Patient

Room Code LNPT

Area M2 15

**Description
Special Requirement**

The Patient Lounge provides for a change of environment away from clinical areas for patients and visitors. It is an area where family groups can visit and patients can socialise. An external outlook is essential.

Acoustics: Sound attenuation level - Medium; Acoustic privacy required.

Body Protected electrical area

Room Fabric and outline specifications

Remarks

1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	Vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl covered skirting
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
7001	Windows				essential
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900mm AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9011	Doors	Solid Core	Paint	1 1/2 leaf, half glazed	1400mm clear opening

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
4900	Metalwork	Curtain track, window	1	1	or blinds
23410	Furniture/ Fitting	Television bracket, wall mounted	1	1	or in cabinet

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
1006	Communications	Voice / Data outlet - double	1	
1090	Communications	TV: MATV	1	optional
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
6046	Lighting	Indirect lighting		optional
8000	Nurse Call	Patient / Nurse call	1	+ indicator button & light
8005	Nurse Call	Patient call handset	1	call button on the handset
8010	Nurse Call	Nurse assist call	1	+ indicator button & light
8080	Nurse Call	Emergency call	1	+ indicator button & light
9000	Power	GPO: Single	4	
9015	Power	GPO: Cleaner	1	
9040	Power	Body protected		
9060	Power	Special: for equipment	1	TV, optional