## **Design Guidelines for Hospitals and Day Procedure Centres**

### **Standard Components Room Data Sheets**

**Room Name** 

**Patient Bay - Holding** 

Room Code PBTR-NA

#### Area M2

9

# Description Special Requirement

A Patient Bed Bay used for holding of patients prior to procedures, recovery of patients following procedures or for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin.

Body Protected electrical area

| Room | Remarks         |              |                         |                           |                                    |
|------|-----------------|--------------|-------------------------|---------------------------|------------------------------------|
| 1000 | Floor finish    | Vinyl        | Standard slip resistant | Seamless, coved           |                                    |
| 2000 | Skirting        | Vinyl        | Prefinished             | Floor vinyl coved, 150mmH |                                    |
| 3000 | Wall finish     | Paint        | Acrylic, washable       |                           |                                    |
| 3092 | Wall protection | MDF          | Laminate                | Bed protection wall panel |                                    |
| 4020 | Wall protection | Composite    | Prefinished PVC         | Crash rail at 900mm AFFL  | As required, equal to<br>'Acrovyn' |
| 4030 | Wall protection | Composite    | Prefinished PVC         | Corner guards to 900H     | As required, equal to<br>'Acrovyn' |
| 5010 | Ceiling         | Plasterboard | Paint, washable         | Flush set, suspended      |                                    |
| 6030 | Cornice         | Aluminium    | Powdercoat              | 24mm shadow angle         |                                    |

#### **Fittings and Furniture**

| Fitting ID | Category           | Fitting                          |   | Quantity | Selection |
|------------|--------------------|----------------------------------|---|----------|-----------|
| 1465       | Furniture/ Fitting | Bracket: suction bottle          | 2 | 1        |           |
| 4600       | Metalwork          | Curtain track, bed               | 1 | 1        |           |
| 6152       | Furniture/ Fitting | Dispenser: disposable glove      | 2 | 1        |           |
| 12900      | Metalwork          | Louvered panel, for storage-bins | 1 | 1        | optional  |

#### Fixtures, Equipment and associated services

| FFE ID | Description                 | Grp | Quantit | Ele | CdW | HtW | WmW | Тар | Dns | Gas | Stm | Selection |
|--------|-----------------------------|-----|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----------|
| 31700  | Light: examination, ceiling | 1   | 1       | yes |     |     |     |     |     |     |     | optional  |

#### **Services**

| Service ID | Service Category | Description                            | Quantity | Remarks                           |
|------------|------------------|--|----------|-----------------------------------|
| 1006       | Communications   | Voice / Data outlet - double           | 1        |                                   |
| 5000       | HVAC             | Heating, Ventilation & Airconditioning |          | Refer to Part E Building Services |
| 6001       | Lighting         | General : colour corrected             |          |                                   |
| 6030       | Lighting         | Special: downlights                    |          | over bed/trolley                  |
| 7000       | Medical Gases    | O2                                     | 1        |                                   |
| 7020       | Medical Gases    | Medical Air                            | 1        | Optional                          |
| 7040       | Medical Gases    | Suction                                | 1        |                                   |
| 8000       | Nurse Call       | Patient / Nurse call                   | 1        | + indicator button & light        |
| 8005       | Nurse Call       | Patient call handset                   | 1        | call button on the handset        |
| 8010       | Nurse Call       | Nurse assist call                      | 1        | + indicator button & light        |
| 8080       | Nurse Call       | Emergency call                         | 1        | + indicator button & light        |
|            |                  |  |          |                                   |



02-Nov-04

Issue 1

# **Design Guidelines for Hospitals and Day Procedure Centres**

# **Standard Components Room Data Sheets**

**Room Name** 

Patient Bay - Holding

Room Code PBTR-NA

| Service ID | Service Category | Description                   | Quantity | Remarks |
|------------|------------------|-------------------------------|----------|---------|
| 9000       | Power            | GPO: Single                   | 2        |         |
| 9010       | Power            | GPO: Single - emergency power | 1        |         |
| 9015       | Power            | GPO: Cleaner                  | 1        |         |
| 9040       | Power            | Body protected                |          |         |

