

Design Guidelines for Hospitals and Day Procedure Centres

Standard Components Room Data Sheets

Room Name **Waiting**

Room Code WAITG

Area M2 10

Description Special Requirement

An area for visitors and patients to wait in comfort prior to or during visits to a Unit. A Waiting area may be for the use of public, patients, families and other visitors to a facility. The Waiting area will require facilities for a range of occupants including adults and children, both able-bodied and disabled. An external outlook is desirable; waiting areas may be shared between Units;

Room Fabric and outline specifications

Room Fabric and outline specifications					Remarks
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom; 48 oz.	vinyl also acceptable
2010	Skirting	Vinyl	Prefinished	Feather edged, 150mmH	or floor vinyl coved skirting
3000	Wall finish	Paint	Acrylic, washable		
4030	Wall protection	Composite	Prefinished PVC	Corner guards to 900H	as required, Equal to Acrovyn
5060	Ceiling	Acoustic	Prefinished	Drop-in tiles, 600x1200	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
7001	Windows				desirable

Fittings and Furniture

Fitting ID	Category	Fitting	Grp	Quantity	Selection
4900	Metalwork	Curtain track, window	1	1	optional
23300	Metalwork	Television bracket	1	1	optional

Fixtures, Equipment and associated services

Services

Service ID	Service Category	Description	Quantity	Remarks
1011	Communications	Telephone: pay phone	1	optional
1090	Communications	TV: MATV	1	optional
5000	HVAC	Heating, Ventilation & Airconditioning		Refer to Part E Building Services
6000	Lighting	General		
9001	Power	GPO: Double	1	
9060	Power	Special: for equipment	2	TV, pay phone - optional